

PCB Management Plan Activities Q4 2022 (April 2022 – June 2022)

Burncoat and Doherty High School

Cleaning:

- Documentation logs for the Custodial accelerated cleaning program were received from Burncoat and Doherty for the months of April, May, and June 2022.
- The Facilities Dept has a cleaning inspection program to conduct random cleaning quality audits in WPS' buildings.

PCB Best Management Quarterly Inspection:

WPS' environmental consultant conducted caulking and dust accumulation assessments at Doherty High on 6/22/2022 and at Burncoat High on 6/23/2022.

Inspection Results

	Burncoat High School	Doherty High School
Number of Areas Inspected	22	29
Number of Areas with Incomplete Over-caulking	3	1
Number of Plenum Vents/ Univents in poor condition	0	0
Areas with dust accumulations	22	10

Remediation:

- WPS Facilities Department reapplied over-caulking to all areas noted in the inspection reports that were either damaged or missing.
- WPS Custodial Staff addressed the areas that were identified to contain dust accumulations at both Doherty and Burncoat High Schools.

Air Testing:

Air testing was performed this quarter at Doherty on 6/22/2022 and at Burncoat on 6/23/2022.

Removal:

Two windows at Doherty High were removed by WPS' abatement contractor and replaced.

Staff and Parent Involvement:

No cleaning or remediation complaints were received or responded to during this time period.

Other Maintenance Activities:

All Doherty univents are cleaned using a HEPA vacuum. All univent air filters are replaced at Doherty High School by the WPS Facilities Department.