



Worcester Public Schools



Worcester, Massachusetts

Sukuu Panyin Ofise

Dr. John E. Durkin Administration
Building

Telefon (508) 799-3115

20 Irving Street

FAX (508) 799-3119

Worcester, Massachusetts 01609-2493

Ayewohomumɔ 2022

De kɔma Sukuufo, Abusuafo, ne Adwumayefo a wɔwɔ **ACT Program**,

Nansa yi ara lead dade ne kɔbere nsuo nhwehwemu mu no, yehuu sɛ doroben ahorow bi a ewɔ yen sukuu mu wɔ lead dade gyinapɛn bi a ɛboro lead dade gyinapɛn a ehia no so ana/ne kɔbere a ɛboro Anamɔntu Gyinapɛn no so. Yesaa nsuo no bi fii doroben ahorow nyinaa mu nea yenom, yɛde noa aduane, ne nea yɛde hwe akwanhosan dwumadie ahorow nansa yi ara efa lead dade ne kɔbere ewɔ nsuo mu nhwehwemu. Yesaa nsuo no bi fii doroben biara mu, yɛaa nsuo a agyina doroben mu ma ade akye anɔpa deɛ a edi kan ne nea yesae bere a woguso sa nsuo no dada. Sɛ wopɛ nsem pii afa akwan ahorow a yefa so sa nsuo wɔ sukuu no mu a mesrɛ wo hwe: <https://www.mass.gov/guides/sampling-for-lead-and-copper-at-schools-and-childcare-facilities>

Nea ene USEPA 3Ts Nhoma a wɔn ayɛ mu Nsakrae hyia no, MassDEP LCCA dwumadie no hyɛ ho nkuran sɛ sukuu ahorow ne mfiase nhomasua ne ɔhwe dwumadie ahorow no yɛ nhwehwemu na wosiesie doroben biara a wɔnom mu nsuo, wɔde noa aduane ne nea wode hwe akwahosan dwumadie ahorow a lead dade resɔt no boro Massachusetts nhwehwemu a wɔn agye atom gyinapɛn 1ppb0.001 milligram lita baako biara (mg/L) (0.001 milligrams per liter (mg/L)) kosi sɛ yebehu lead dade a esua koraa. Massachusetts Anamɔntu Gyinapɛn ma kɔbere a ewɔ nsuo mu yɛ 1.3 mg/L (yɛsan frɛ no parts per million).

Sɛ wopɛ MassDEP ho nsem a efa lead dade ne kɔbere a ewɔ nsuo mu a hwe:

Lead Dade: <https://www.mass.gov/lead-in-drinking-water>

Kɔbere: <https://www.mass.gov/doc/fact-sheet-copper-and-your-health>

Sɛ wopɛ Massachusetts Asoɛe a ehwe Amansan Akwahosan ho nsem a efa lead dade ne kɔbere a ewɔ nsuo mu a hwe: <https://www.mass.gov/orgs/childhood-lead-poisoning-prevention-program>

Nhwehwemu Resɔt ne Eho Dwumadie Nhyehyɛɛ

Nhwehwemu Da	Doroben Ahorow a yehwehwemu	Nhwehwemu Beae	Lead Dade resɔt mg/L	Lead Dade resɔt wɔ anibu	Kɔbere resɔt mg/L	Kɔbere resɔt wɔ anibu 30 akyia	Dwumadie Nhyehyɛɛ
4/20/2022	Sukuudan mu nsuo duroben	Dan 1154B	Enni Hɔ	Enni Hɔ	1.7	0.56	Fa ahyensodeɛ "Hohoro wo Nsa Nkoaa" si hɔ

Massachusetts nhwehwemu a wɔn agye atom gyinapɛn yɛ 0.001 mg/L ne Anamɔntu Gyinapɛn ma kɔbere yɛ 1.3 mg/L

Worcester Public Schools (WPS) no fa saa resots wei anibere paa na yerefa akwan ahorow so asiesie nea aba no. Yene MassDEP nyinaa reye adwuma abom.

Nea eka anamontuo a ewo wo sukuu mu ho no, WPS reye dwumadie ahorow yi wo mantam no nyinaa mu:

1. Wo ahyensodee bi te se "Nsa Hohoro Nkoa Ahyensodee" asi doroben ahorow a lead dade ne/kobere gyinapen no boro lead gyinapen no so ne/anaa kobere Anamontuo Gyinapen no so na wonnom nsuo no anaa wommfa noa aduane. Doroben dodow no ara a eboro anamontuo gyinapen no so wo mantam no mu ye kyensee a yede hohoro nsa. Massachusetts Asoee a Ehwε Akwahosan so no ka se nsuo a lead dade ne kobere wom no nye hu bere a wode hohoro wo nsa.
2. Yebema sukuufo, adwumayefo, ne mpotam adwumayefo nsem.
3. Yene WPS asoee te se Aduanedi, Nεesin, ne nea etete saa na yede aye anamontuo nhyehyee, se eho behia a.
4. Yehwe se yewo nsuo dodow a yenom ne nea yede ye aduane se ese se yeyi doroben bi kakra na yeye nhwehwemu a anaa yede yiye to n'akwan mu. Yadum nea ema nsuo ye nwunu nyinaa, doroben a yenom mu nsuo, ne tua ahorow nyinaa ansaa na yeba sukuu mu besua ade bio wo Obenim 2021. Tua mu nsuo wo ho ma asukuufo nyinaa ne adwumayefo nyinaa saa bere yi.

Lead Dade ne Kobere a ewo Nsuo a Yenom mu Farebea ne Nhwehwemu

Wo Massachusetts no, nsuo a yenom dodow no ara a efi nsukurabea ne asaase ase nsuo nni lead dade ne kobere wom. Lead dade tumi ko nsuo mu bere a nneema a wode twe nsuo no ho aka na ewo lead dade wom, te se lead doroben (doroben biara a ewo lead wom no yayi afi ho) a efi dan bi mu ko nsuo mu wo abonten so, anaa nea efi nneema a yede twe nsuo wo dan bi mu. Kobere tumi ko nsuo mu bere a nneema a wode twe nsuo no ho aka na ewo kobere wom.

Lead dade ne kobere a esone taa si bere a nsuo no aye hye anaa egyina faako, titiriw bere a ade akye so anaa bere a womfaa nsuo no nni dwuma nnonhwerew pii. Ne saa enti, MassDEP hwehwe se wotwe nsuo a ade akye so anopa no ne bere a obiara amfa nsuo no anni dwuma anadwo mu no nyinaa.

Nkaebo a efi MassDEP

Nsuo a efi sukuumu no ntesε nsuo a ewo dan afoforo mu. Nneema a yede twe nsuo ne doroben ahorow, titiriw, nea wode lead dade na aye anaa nea yede tare dade betumi ama kwan ama lead dade awura nsuo mu.

Mesre wo hye no nso se asiane nsem a efa Covid-19 ho enti, yemfa nneema bi te se nea ema nsuo ye nwunu, asubura a wonom mu nsuo, ne nsuo tua ahorow nni dwuma bio wo mfe mmienu a etwam ni. Yen ama adwumayefo ne asukuufo nyinaa nsuo a ewo tua mu fi bere a yebaa sukuu se yebesua ade wo March 2021. Yereye adwuma dendenden na y'aye nsuo a yenom nyinaa mu nhwehwemu wo yen dan ahorow nyinaa mu na yetumi de adi dwuma 2022 – 2023 sukuu afe no.

Se wope nsemmissa biara a efa saa asem yi ho a, mesre wo fre WPS Nneema Asoee wo (508) 799-3151.

Eye me,



Sukuu Panyin