



Worcester Public Schools

Worcester, Massachusetts



Office of the Superintendent

Dr. John E. Durkin Administration
Building
20 Irving Street
Worcester, Massachusetts 01609-2493

Tel. (508) 799-3115

FAX (508) 799-3119

June 2022

To the Students, Families, and Staff of **University Park Campus School**,

Samples were collected from taps and fixtures used for drinking, cooking, and medical uses during recent lead and copper water sampling. Samples were taken at each tap or fixture for both a first draw sample with the water standing in the tap overnight as well as a flushed sample after the tap was run. For information on sample collection procedures for school samples please see: <https://www.mass.gov/guides/sampling-for-lead-and-copper-at-schools-and-childcare-facilities>

We are pleased to report that all samples taken from the taps and fixtures contain no measurable lead concentrations and are below the Massachusetts Action Levels for copper in drinking water.

In accordance with the USEPA's Revised 3Ts Manual, MassDEP's LCCA program recommends that schools and early education and care programs evaluate and remediate all taps/fixtures used for drinking, food preparation or medical uses with lead results above the Massachusetts certified laboratory detection limit of 1ppb (0.001 milligrams per liter (mg/L)) until the lowest possible concentration of lead is achieved. The Massachusetts Action Level for copper in drinking water is 1.3 mg/L (also known as parts per million).

For MassDEP information on lead and copper in drinking water see:

Lead: <https://www.mass.gov/lead-in-drinking-water>

Copper: <https://www.mass.gov/doc/fact-sheet-copper-and-your-health>

For Massachusetts Department of Public Health information on Lead and Copper see:

<https://www.mass.gov/orgs/childhood-lead-poisoning-prevention-program>

Sources and Sampling of Lead and Copper in Drinking Water

In Massachusetts, most drinking water sources from reservoirs and groundwater do not contain elevated levels of lead or copper. Lead enters drinking water primarily by leaching from plumbing that contains lead, such as a lead service line (all known lines containing lead have been removed) that connects a building to the water main in the street, or from plumbing and fixtures inside a building. Copper enters drinking water primarily by leaching from plumbing that contains copper.

Lead and copper leaching is most likely to occur when the water is heated or is not moving, generally overnight or at other times when the water is not used for several hours. Therefore, MassDEP requires the fixtures to be sampled first thing in the morning after the water in the building has not been used overnight.

A Reminder from MassDEP

The water system at the school is not unlike water systems found in other buildings. Older plumbing systems and fixtures, especially, can contain lead pipes or solder that can allow lead to enter tap water.

Please note that due to concerns regarding Covid-19, fixtures such as water coolers, drinking fountains, and bottle fillers have been offline and unavailable for use over the last two years. Bottled water has been provided to all staff and students since the return to in-person learning in March 2021. We are diligently working to evaluate all drinking water sources in our buildings to make them available for use during the upcoming 2022 – 2023 school year.

If you have any questions on this information, please contact the WPS Facilities Department at (508) 799-3151.

Sincerely,

Handwritten signature of Rachel H. Monahan in black ink.

Superintendent of Schools